



STUDIO WINTER

Chartered Architect

The Guildhall, Liskeard
Cornwall PL14 3JE

Tel: 01579 345354

Fax: 01579 347527

www.studiowinter.com

mail@studiowinter.com

Development Control
Cornwall Council
Chy Trevail
Beacon Technology Park
Bodmin
Cornwall PL31 2FR

27th August 2019

our ref: 19/1537 Alterations to Internal Fire Doors at The Guildhall, Liskeard
your ref:

Works to Doors

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|------------------------------|------------------------------------|--|
| D0/1 | Rear of Beddoe's Fruit & Veg | C20th painted timber, flush finish | Replace door with FD30 flush finish painted timber door with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit new overhead AD:M compliant fire rated closer, fit new sound activated fire alarm linked magnetic holdback |

Door Photograph(s):



(view from northeast)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|-------------------------------|------------------------------------|--|
| D0/2 | Rear of Pengelly's Fishmonger | C20th painted timber, flush finish | Replace door with FD30 flush finish painted timber door with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit 10mm fire & smoke intumescent strip to door edges, fit new overhead AD:M compliant fire rated closer |

Door Photograph(s):



(view from southwest)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|------------------------|---|--|
| D0/3 | Rear of Treatment Room | C20th painted timber, flush finish with foam panel covering | Replace door with FD30 flush finish painted timber door with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit 10mm fire & smoke intumescent strip to door edges, fit new overhead AD:M compliant fire rated closer |

Door Photograph(s):



(view from west)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|------------------------|--|---|
| D0/4 | Rear of DVD Store Room | C19th painted timber, top ½ glazed (hardboard cover panel both sides) bottom 2 panel | Cover door on both sides with timber 50x75mm stud wall faced with Gyproc Fireline skimmed & decorated to provide 60min fire resistant partition |

Door Photograph(s):



(view from north)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|--------------------------|------------------------------------|---|
| D0/5 | Beddoe's Cold Store Room | C20th painted timber, flush finish | Replace door with FD30 flush finish painted timber door with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit new overhead AD:M compliant fire rated closer, fit new GEOFire Agripper sound activated magnetic holdback |

Door Photograph(s):



(view from east)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|-----------------------------------|--|--|
| D1/1 | North Stair West Inner Door | C20th painted timber, flush finish | <p>Replace door with FD60 flush finish painted timber door with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit 20mm fire intumescent strip to door edges, fit new panic bar & lever</p> <p>Replace wall & underside stair plasterboard over door with 60min fire rated Gyproc Fireline skim & decorate</p> |

Door Photograph(s):



(view from north)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|-----------------------------|---|--|
| D1/2 | North Stair East Inner Door | C20th painted timber, flush finish with glazed fan light over | <p>Replace door with FD60 flush finish painted timber door with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit 20mm fire intumescent strip to door edges, fit new panic bar & lever</p> <p>Cover fanlight on both sides with facing of Gyproc Fireline skimmed & decorated to provide 60min fire resistance</p> <p>Replace wall & underside stair plasterboard over door with 60min fire rated Gyproc Fireline skim & decorate</p> |

Door Photograph(s):



(view from north)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|------------------------------------|--|---|
| D2/1 | Mid North Stair Utilities Cupboard | C19th painted timber 1 panel cupboard door | Fire stop vertical service void within cupboard with 120min fire rated insulation batt & mastic seals max. 25mm wide to perimeter |

Door Photograph(s):



(view from west)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|--------------------------------|--|--|
| D2/2 | Studio Winter North Stair Door | C19th painted timber 6 panel (both sides) door | Fit new 3no. 100mm butt fire rated hinges with intumescent packers behind, remove existing 10mm smoke seal to door edges & fit 20mm fire & smoke intumescent strip to door edges, check timber panels min. 10mm thick, decorate in Envirograf 60min fire rated paint |

Door Photograph(s):



(view from west)



(view from east)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|----------------------------|---|--|
| D2/3 | Mid North Stair South Door | C19th painted timber 4 panel (south side) 6 panel (north side) door | Fit new 3no. 100mm butt fire rated hinges with intumescent packers behind, remove existing 10mm smoke seal to door edges & fit 20mm fire & smoke intumescent strip to door edges, check timber panels min. 10mm thick, decorate in Envirograf 60min fire rated paint |

Door Photograph(s):



(view from south)



(view from north)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|-------------------------------|-----------------------------------|--|
| D2/4 | Electricity Meter Cupboard(s) | C20th painted timber flush finish | Face rear of each existing cupboard door with 30min fire rated board, remove strip twist catches, make/fit/decorate new door to match for top left opening, mastic fire seal service holes in cupboard through walls/floor/ceiling |

Door Photograph(s):



(view from southwest)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|--------------------|---|--|
| D2/5 | Gym Northwest Door | C19th painted timber 4 panel (west side) 6 panel (east side) door | Fit new 3no. 100mm butt fire rated hinges with intumescent packers behind, remove existing 10mm smoke seal to door edges & fit 20mm fire & smoke intumescent strip to door edges, check timber panels min. 10mm thick, decorate in Envirograf 60min fire rated paint |

Door Photograph(s):



(view from northwest)



(view from east)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|---------------------------|--|--|
| D2/6 | West Stair Top Inner Door | C20th painted timber, G/O flush finish with vision panel | Replace door with G/O FD30 flush finish painted timber door with single vision panel with new 3no. 100mm butt fire rated hinges with intumescent packers behind & fit 10mm fire & smoke intumescent strip to door edges, fit new overhead AD:M compliant fire rated closer |

Door Photograph(s):



(view from north)



(view from south)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|--------------------|---|--|
| D2/7 | Top of South Stair | Pair C20th half glazed (Georgian wire) painted timber, single panel below with fan light over | <p>Replace pair doors with G/O FD30 flush finish painted timber doors with new 3no. 100mm butt fire rated hinges with intumescent packers behind, fit 20mm fire intumescent strip to door edges, fit new panic bars & levers</p> <p>Cover fanlight on both sides with facing of Gyproc Fireline skimmed & decorated to provide 60min fire resistance</p> |

Door Photograph(s):



(view from west)



(view from east)

Cont'd/...

| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|----------------|-------------------|---|
| D2/8 | South Stair | Metal Grill | Fire stop atop metal grill within stairwell with 120min fire rated insulation batt & mastic seals max. 25mm wide to perimeter |

Door Photograph(s):



(view from east)

Cont'd/...



| Door Reference: | Door Location: | Door Description: | Proposed Works: |
|-----------------|-------------------|-----------------------------------|--|
| D3/1 | Balcony Sore Room | C19th painted timber 4 panel door | Fit new 3no. 100mm butt fire rated hinges with intumescent packers behind, remove existing 10mm smoke seal to door edges & fit 20mm fire & smoke intumescent strip to door edges, check timber panels min. 10mm thick, decorate in Envirograf 60min fire rated paint |

Door Photograph(s):



(view from northwest)



(view from east)